


August 16 2022

Mock up report - Kensington Market Pedestrian Lighting

Mock up date: Wednesday August 10, 2022, 8-10pm
Location: 64 Oxford Street / patio of Urban Herbivore, along Augusta
Submitted by: Deborah Gottesman, Gottesman Associates



1. The ANP luminaire (with the "hat" and opal lens) was the aesthetic that was preferred by most who voted. The underside of the hat should be white to give luminaire better presence.
2. The Ligman luminaire was presented as a light column (no hat, clear lens), however it has very good performance and is robust. This luminaire is available with the same aesthetic (hat and opal lens) and is still under consideration for this project.
3. The HCI fixture was deemed to be of inferior construction and optical quality and is not in contention.
4. There was some discussion and requests by stakeholders for dimming. Gottesman/Summit to investigate possibility and affordability within budget.
5. Warmer colour temperature of 2700K is preferred.
6. Concern was raised for turning off the lights at a curfew as undesirable activities still occur after businesses close. We advised that the curfew time, if any, will be up to the BIA to determine.
7. A request was made by stakeholders to illuminate the laneways as well, however that is outside of scope of the project.
8. Finish colour of luminaires and poles was raised – we advised that typically black, white, and some form of grey are usually standard colours. We suggested putting preference colour on ballots, which some did. Also an anti-graffiti coating was suggested by stakeholder.

Follow up:

1. Gottesman to run calculations to compare the ANP luminaire (preferred by most) and the Ligman luminaire (the light column); the Ligman can be configured similarly to the ANP (ie with a hat and the opal lens) and if performance is similar then the spec can have two options. A competitive situation is advantageous for the tender.
2. Summit/Gottesman will investigate whether the City still recommends a 2' concrete base on Augusta and Kensington; given that the fixtures will be located at the house side of the sidewalks, there is less risk of damage by cars and snowplows etc..
3. Summit/Gottesman will investigate dimming options and advise.



Tabulation of ballots - KMBIA mock up August 10 2022

Ballot Rankings			
ANP	HCI	Ligman	Comments
1	2	3	Black with white undercap
1	2	3	Grey colour
1	2	3	
1	2	3	
1	2	3	
1	2	3	white underside of cap, black fixture and pole
1	2	3	
3	1	2	
1	3	2	2.3K, white lens; 2 to 3' lower, add a round bar to stop a bat (at bottom)
3	1	2	
1	2	3	
1	2	3	
1	2	3	
1	2	3	
1	2	3	

Rank in order of preference
1-favourite, 3-least favourite